

TPB01

Temporary Power Box

AS/NZS 3012:2010 Compliant



- › Ideal for Temporary Power to building and small construction sites
- › Complies with **“AS/NZS 3012:2010 Electrical Installations- Construction and Demolition Sites”**

Christchurch Office
388-396 Tuam Street,
Phillipstown,
Christchurch 8011,
New Zealand
P +64 3 335 0366
F +64 3 335 0980
E sales@pdc.co.nz

Northern Region/Auckland
9 Levene Place
Mt Wellington
Auckland 1060
New Zealand
P +64 9 526 7881
F +64 9 525 5799
E sales@pdc.co.nz

pdc
ELECTRICAL ENGINEERED SOLUTIONS

TPB01

Temporary Power Box

AS/NZS 3012:2010 Compliant



AS/NZS 3012:2010 COMPLIANT FEATURES

- ✓ IP 23
- ✓ Robust Enclosure - Powder Coated Steel Enclosure
- ✓ Lockable Door
- ✓ Door Stay to hold the door open
- ✓ Safety and warning labels inside and outside of the Enclosure
- ✓ Fitted with a stay beside cable entry on the bottom so the flexible leads can be secured to it

ADDITIONAL FEATURES

- > Top hinged door providing weather protection when in use
- > Double 15A Socket for use by Welders and Sanders
- > Socket Outlets protected by a 25A RCBO and no exposed wiring
- > Provision for meter if required by Power Authority
- > Door can close and lock in use
- > Can be easily screwed to wooden post or fence
- > Able to be reused a number of times